

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-08234
Name of Facility: Orchard Villa El.
Address: 5720 NW 13 Avenue
City, Zip: Miami 33142

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: M-DCSB Food and Nutrition
Person In Charge: M-DCSB Food and Nutrition Phone: (786) 275-0400
PIC Email:

Inspection Information

Purpose: Routine
Inspection Date: 6/13/2022

Begin Time: 04:00 PM
End Time: 05:00 PM

Additional Information

FEMALES 126 CENSUS 248
MALES 122

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
OUT 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	IN 16. Showers Water Temperatures	NA 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
OUT 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

Satisfactory.

Email Address(es): pclermont@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #2. Playground, Equipment & Athletic Fields

At the time of this inspection, a hole was observed in the carpet at the Playground. Repair hole.

CODE REFERENCE: 2. Playgrounds, Equipment and Athletic Fields. 5(2)(k) SREF. Playgrounds, equipment, and athletic fields where provided, shall be maintained in a safe and acceptable condition for the intended function. 5(2)(k)1 SREF. Play areas and athletic fields where fencing is provided shall comply with SREF, Section 5(2)(d). 5(2)(k)2 SREF. Pre-K, kindergarten, or day-care play areas, where provided, shall have direct access to and from their related classrooms or to a corridor providing immediate and safe access to the play area. 5(2)(k)3 SREF. Play areas and athletic fields, where provided, shall have either direct access from the facility without crossing roads, traffic lanes, drives, or parking lots, or have appropriate safety devices provided where access crosses parking areas or drives. 5(2)(a)8 SREF. The playground shall be graded and drained to prevent an unintentional accumulation of standing surface water and debris. 468.2.2 FBC. Playground and equipment shall be safe, structurally sound, vermin proof, and shall not have jagged or sharp projections. Playground equipment shall be anchored to prevent toppling or dislodgement. Cushioning materials such as mats, wood chips, or sand shall be used under climbing equipment, slides, and swings.

Violation #5. Maintenance & Repair

At the time of this inspection, ceiling tiles were observed missing at room 224. Provide Ceiling tiles.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #6. Lighting Standards

At the time of this inspection, several lightbulbs out were observed at rooms: 125,123,118 and 239. Replace lightbulbs.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Inspection Conducted By: Pedro Hernandez Bastidas (913251)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name:
Date: 6/13/2022

Inspector Signature:

Handwritten signature of Pedro Hernandez Bastidas.

Client Signature:

Handwritten signature of the client.